

Air Leakage, Water Permeability, Resistance against the wind according to CE standard UNI EN 14351-1:2010 of opening window		
NAME OF SAMPLE: ONE - SASH HINGED OPENING WINDOW - ZEUS-200		
TEST OFFICIAL NAME	CLASSIFICATION	COMMENTS
Air Leakage	A4	TOP CLASS 3m ³ /(h x m ²) at reference pressure 100pa
Water permeability	7A	300 Pa Pressure
Resistance against the wind	C5	TOP CLASS 2000 Pa Pressure
NAME OF SAMPLE: SLIDING WINDOW - ZEUS-500		
TEST OFFICIAL NAME	CLASSIFICATION	COMMENTS
Air Leakage	A2	27m ³ /(h x m ²) at reference pressure 1000pa
Water permeability	3A	100 Pa Pressure
Resistance against the wind	C5	1600 Pa Pressure